

**REQUEST FOR PROPOSAL**  
**PROJECT NO. RFP-C 19-34**  
**VARIOUS LINCOLN EQUIPMENT**  
**QUESTIONS AND ANSWERS No. 001**

Date: January 9, 2019

To: Prospective Respondents

From: Procurement Operations Department, Houston Community College

Subject: Questions and Answers Responses

---

Q1. Please confirm the Shipping and Place of Performance.

**Response:** Shipping locations will be described on each individual Purchase Order. The locations are:

Houston Community College  
Attn: Alberto Urbina  
6815 Rustic  
Houston, Texas 77087

Houston Community College  
Attn: Alberto Urbina  
1300 Holman  
Houston, Texas 77004

Houston Community College  
Attn: Alberto Urbina  
1990 W. Airport  
Houston, Texas 77051

Q2. Please clarify the installation specifications for this solicitation.

**Response:** The welding machines will need 3-Phase 460-volt power supply.

Q3. Will the delivery require a lift gate?

**Response:** Yes, the delivery will require a lift gate.

Q4. Do all of these items need to be installed?

**Response:** Yes, each welding machine will need to be installed.

Q5. Does your old equipment need removal?

**Response:** No.

Q6. Are the final connections ready for installation?

**Response:** Junction boxes are installed, but wire from junction to welding machines will need to be installed.

Q7. Will any plumbing or electrical work be required for installation?

**Response:** Yes, electrical work will be required for installation.

Q8. What is the anticipated date (approximately) of award and submission of purchase order for the total amount of items called for in RFP-C 19-34?

**Response:** Within 60 days after receipt of proposals.